



- ⑥G ~ #6 AWG STRANDED BARE COPPER GROUND WIRE
- ④G ~ #4 AWG STRANDED BARE COPPER GROUND WIRE
- ①A ~ 2/C #4 AWG DUCT CABLE
- ①B ~ 4/C #4 AWG DUCT CABLE
- ①C ~ 2/C #6 AWG DUCT CABLE
- ①D ~ 4/C #6 AWG DUCT CABLE
- ①E ~ 3/C #4 AWG DUCT CABLE NEEDED FOR 1 PHASE 240/480
- ①F ~ 6/C #4 AWG DUCT CABLE NEEDED FOR 480v 3 Phase
- ①H ~ 3/C #6 AWG DUCT CABLE NEEDED FOR 1 PHASE 240/480
- ①I ~ 6/C #6 AWG DUCT CABLE NEEDED FOR 480v 3 Phase

SPECIFICATION	CATEGORY CODE ITEMS										
APPROVED	DIRECTOR - OFFICE OF TRAFFIC AND SAFETY										
SHA State Highway Administration	<table> <tr> <td>APPROVAL • SHA REVISIONS</td><td>APPROVAL • FEDERAL HIGHWAY ADMINISTRATION</td></tr> <tr> <td>APPROVAL 7-1-94</td><td>APPROVAL 7-1-94</td></tr> <tr> <td>REVISED 10-1-01</td><td>REVISED 2-1-01</td></tr> <tr> <td>REVISED</td><td>REVISED</td></tr> <tr> <td>REVISED</td><td>REVISED</td></tr> </table>	APPROVAL • SHA REVISIONS	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION	APPROVAL 7-1-94	APPROVAL 7-1-94	REVISED 10-1-01	REVISED 2-1-01	REVISED	REVISED	REVISED	REVISED
APPROVAL • SHA REVISIONS	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION										
APPROVAL 7-1-94	APPROVAL 7-1-94										
REVISED 10-1-01	REVISED 2-1-01										
REVISED	REVISED										
REVISED	REVISED										

Maryland Department of Transportation

STATE HIGHWAY ADMINISTRATION

STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES

LIGHTING LEGEND

STANDARD NO.

MD 800.01-04